

COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**FIREFIGHTER 1 PERFORMANCE EVALUATION**



JPR Task: Inspection of SCBA

Candidate # \_\_\_\_\_

Skill No. **1-5** **PERFORMANCE CRITERIA AND INSTRUCTIONS**

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. Proper location in which to perform.
2. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"The candidate shall demonstrate inspection of an SCBA for use."

Minimum PPE: Full PPE including SCBA.

**PERFORMANCE**

Candidate must complete this skill within **5** minutes to pass.

YES NO

C	1. Identifies and inspects all components of SCBA for cleanliness and damage.	<input type="checkbox"/>	<input type="checkbox"/>
C	2. Cleans components as necessary, removes damaged components from service and notifies officer.	<input type="checkbox"/>	<input type="checkbox"/>
C	3. Ensures cylinder is full (at least 90%).	<input type="checkbox"/>	<input type="checkbox"/>
C	4. Opens cylinder valve completely, verifies operation of low air alarm and absence of leaks.	<input type="checkbox"/>	<input type="checkbox"/>
C	5. Leaks corrected if possible, otherwise unit is removed from service and the officer notified.	<input type="checkbox"/>	<input type="checkbox"/>
C	6. Ensures gauges or indicators are within acceptable ranges.	<input type="checkbox"/>	<input type="checkbox"/>
C	7. Checks PASS device function.	<input type="checkbox"/>	<input type="checkbox"/>
C	8. Checks face piece for seal and function.	<input type="checkbox"/>	<input type="checkbox"/>
C	9. Checks bypass or purge valve, if applicable.	<input type="checkbox"/>	<input type="checkbox"/>
C	10. Places SCBA components in ready status for next use to reduce the loss of life and/or property.	<input type="checkbox"/>	<input type="checkbox"/>

C Candidate performed skill in a safe manner.

Yes-  No-

Text Reference: IFSTA Essentials 5th Edition, Chapter 5

TOTALS

<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------

C = Critical Step- Failure on this step mandates failure on task!

PASS

FAIL

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

10



NFPA 1001:2008 Edition

Objective(s): 5.5.1, 5.5

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**FIREFIGHTER 1 PERFORMANCE EVALUATION**



JPR Task: Don SCBA Over the Head Method

Candidate # \_\_\_\_\_

Skill No. **1-2** PERFORMANCE CRITERIA AND INSTRUCTIONS

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. Proper location in which to perform.
2. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"The candidate, while wearing PPE and using their personal SCBA, shall demonstrate proper over-the-head donning and activation of an SCBA within 1 minute."

Minimum PPE: Full PPE including SCBA.

**PERFORMANCE**

Candidate must complete this skill within **1** minute to pass.

YES NO

<b>C</b>	1. Positions unit with valve end away from body.		
<b>C</b>	2. Opens cylinder valve fully.		
<b>C</b>	3. Compares cylinder and regulator gauge pressures. Notes they are to be within 100 psi.		
<b>C</b>	4. Raises SCBA overhead, guiding straps and elbows into position.		
<b>C</b>	5. Allows SCBA to slide down the back.		
<b>C</b>	6. Fastens all straps and adjusts shoulder straps.		
<b>C</b>	7. Dons face piece, adjusts straps as necessary.		
<b>C</b>	8. Checks and achieves seal.		
<b>C</b>	9. Connects regulator to face piece, receives air.		
<b>C</b>	10. Activates PASS device.		
<b>C</b>	11. Completes ensemble of hood, helmet and gloves.		
<b>C</b>	12. Donning completed in 1 minute.		
<b>C</b>	13. No skin exposed.		

**C** Candidate performed skill in a safe manner.

Yes-  No-

Text Reference: IFSTA Essentials 5th Edition, Chapter 5

TOTALS

**C = Critical Step-** Failure on this step mandates failure on task!

**PASS**  **FAIL**

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL. **13**

NFPA 1001-2008 Edition

Objective(s): **5.3.1**

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY

# COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION FIREFIGHTER 1 PERFORMANCE EVALUATION



JPR Task: Carry, Raise and Position a Single Ladder

Candidate # \_\_\_\_\_

One Firefighter Method

Skill No. **1-24** PERFORMANCE CRITERIA AND INSTRUCTIONS

### INSTRUCTIONS TO THE MONITOR/EVALUATOR

Candidate shall be provided with the following:

1. Proper location in which to perform.
2. The candidate shall be provided with a straight or roof ladder to perform these tasks.
3. The candidate shall be given the instructions below before beginning this task.

### INSTRUCTIONS TO THE CANDIDATE

"The candidate, wearing full PPE and given a ladder, shall demonstrate the proper techniques for Carrying, Raising and Positioning a single straight ladder."

Minimum PPE: Full PPE w/o SCBA

### PERFORMANCE

Candidate must complete this skill within **5** minutes to pass.

YES NO

#### Carry Ladder

C	1. Positions self near center of ladder.		
C	2. Kneels beside ladder, facing tip end, on knee nearest ladder.		
C	3. Grasps ladder and stands ladder on edge (beam).		
C	4. Stands up while lifting ladder, lifts with legs keeping back straight.		
C	5. As ladder is brought up, pivots body to face butt end and rests ladder beam on shoulder.		
C	6. Ladder placed into position for carrying, on shoulder, arm through rungs, both hands grasping ladder.		
	7. Ladder is carried, butt lowered slightly, to the work site for raising.		

#### Raise/Position Ladder

C	8. Observes for solid, level footing area, overhead wires/obstructions and structural stability.		
C	9. Lowers butt to ground, places spurs against structure.		
C	10. Raises ladder, hand over hand on rungs, from beneath ladder.		
	11. Continues raising until ladder is upright against structure.		
C	12. Steadies ladder while pulling butt end out from wall for positioning.		
C	13. Positions to appropriate climbing angle.		

C Candidate performed skill in a safe manner.

Yes-

No-

Text Reference: IFSTA Essentials 5th Edition, Chapter 10

TOTALS

C = Critical Step- Failure on this step mandates failure on task!

PASS

FAIL

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

11

NFPA 1001:2008 Edition

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

Objective(s): 5.3.6

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**FIREFIGHTER 1 PERFORMANCE EVALUATION**



JPR Task: Assist Conscious Victim Down Ground Ladder

Candidate # \_\_\_\_\_

Skill No. **1-27** PERFORMANCE CRITERIA AND INSTRUCTIONS

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. Proper location in which to perform. Assistant to heel ladder.
2. The candidate shall be provided with a ground ladder, raised in place and heeled.
3. The candidate shall have a "victim" on the ladder, at window sill ready to be assisted down.
4. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"The candidate, provided a ground ladder in place, raised and heeled, shall demonstrate procedures for assisting a conscious victim down the ladder from a height of at least 12 feet."

Minimum PPE: Full PPE and SCBA

**PERFORMANCE**

Candidate must complete this skill within **5** minutes to pass.

YES NO

	YES	NO
C 1. Checks for proper climbing angle.		
C 2. Ensures ladder is heeled, secure and that locks are fully engaged.		
C 3. Ascends the ladder to the victim, positions self on ladder, both feet on 1 rung.		
C 4. Has victim face building, places self behind and slightly below the victim.		
C 5. Candidate places forearms under victims armpits and grasps ladder rungs.		
C 6. Begins descent, calms victim, assures victim candidate is in control, directs victim to descend one rung at a time.		

C Candidate performed skill in a safe manner. Yes-  No-

Text Reference: IFSTA Essentials 5th Edition, Chapter 10

TOTALS

C = Critical Step- Failure on this step mandates failure on task!

PASS  FAIL

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL. **6**


NFPA 1001:2008 Edition

Objective(s): 5.3.9

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_



COMMONWEALTH OF KENTUCKY  
 COMMISSION ON FIRE PROTECTION PERSONNEL STANDARDS AND EDUCATION  
**FIREFIGHTER 1 PERFORMANCE EVALUATION**



JPR Task: Construct a Catch All

Candidate # \_\_\_\_\_

Skill No. **1-58** PERFORMANCE CRITERIA AND INSTRUCTIONS

**INSTRUCTIONS TO THE MONITOR/EVALUATOR**

Candidate shall be provided with the following:

1. Proper location in which to perform.
2. The candidate shall be provided with a salvage cover and assistance to perform skill.
3. The candidate shall be given the instructions below before beginning this task.

**INSTRUCTIONS TO THE CANDIDATE**

"The candidate, wearing work gloves and with assistance, shall demonstrate the proper technique of constructing a catch all from a salvage cover."

Minimum PPE: Work Gloves

**PERFORMANCE**

Candidate must complete this skill within **15** minutes to pass.

YES NO

	YES	NO
C 1. Lays cover out flat for folding.		
C 2. Rolls 2 opposing sides inward approximately 3 feet toward center of cover.		
C 3. Folds the corners of the unrolled ends, at a 90 deg angle on top of the cover.		
C 4. Beginning at the outermost point, roll the folded ends toward the center to edge of flaps.		
C 5. Tuck and lock all four corners to secure and prevent leakage.		

C Candidate performed skill in a safe manner. Yes-  No-

Text Reference: IFSTA Essentials 5th Edition, Chapter 17

TOTALS

C = Critical Step- Failure on this step mandates failure on task!

PASS  FAIL

CANDIDATE MUST COMPLETE STEPS TOTAL TO PASS SKILL.

**5**

NFPA 1001:2008 Edition

TEST DATE \_\_\_\_\_ LOCATION: \_\_\_\_\_

Objective(s): **5.3.14**

EVALUATOR NAME (Print): \_\_\_\_\_

EVALUATOR SIGNATURE: \_\_\_\_\_